

BOQ FOR AIR-CONDITIONING WORKS FOR STATE BANK OF INDIA BRANCH AT BAWANA, DELHI.					
S. No.	Description	Unit	Qty.	Rate	Amount
	<b>AIR CONDITIONERS</b>				
1	Supplying, erection, testing and commissioning following wall mounted Split/ Root mounted cassette units of (Toshiba/ Mitsubishi/ Hitachi/ Daikin/O-General/Carrier/Bluestar) with cordless remote complete with all necessary fittings duly insulated with 9 mm thick nitrile rubber pipe insulation with <b>(All coil – copper only)</b> , fan and fan motor, machine control panel improved Refrigerant Joints, .Air conditioners shall be fitted with hermetically sealed type suction cooled reciprocating or discharge cooled rotary compressor or scroll compressor. Compressor unit operating on R32/ R-410. All complete as per drawing, approval and instructions of the Architect/ Employer (Rates to be inclusive of Copper refrigerant pipe with insulation and Drain pipe up to 3 Mtr length). <b>Item to include powder coated outdoor stands as per the manufacturer specifications.</b>				
a	1.0 TR wall mounted split unit (Minimum 5-Star rating inverter type) <b>(ATM Room)</b>	Nos.	2.00		
b	1.5 TR wall mounted split unit (Minimum 5-Star rating inverter type) <b>(BM Cabin)</b>	Nos.	1.00		
c	2.0 TR Ceiling suspended Cassette type <b>3 star rating inverter</b> split unit with 4 way air flow including upto 3.0 mtr. copper refrigerant & drain pipe including installation. <b>(Banking Hall Area)</b>	Nos.	4.00		
d	3.0 TR Ceiling suspended Cassette <b>3 star rating inverter</b> type split unit with 4 way air flow including upto 3.0 mtr. copper refrigerant & drain pipe including installation. <b>(Banking Hall Area)</b>	Nos.	2.00		
2	<b>EXTRA REFRIGERANT PIPING</b>				
	Supplying and laying of Extra copper refrigerant piping with nitrile rubber pipe insulation, both of size as specified by the manufacturer suitable for 1.0/1.5/ 2.0 TR Split type AC and 2.0 TR/ 3.0 TR/4.0 TR Cassette AC - From Indoor to outdoor Units (make as approved by Architect/Bank)				
a	For 1.5TR/ 1.0 TR as specified by the manufacturer	Mtr.	30.00		
b	For 2.0/3.0 TR Cassette as specified by the manufacturer	Mtr.	95.00		
3	<b>DRAIN PIPING</b>				
	Providing and fixing drain piping up to drain as directed by the engineer incharge with all accessories e.g. elbows, unions, sockets, reducers, reducing tees, nipples etc. Complete job including cutting chiseling in walls, floor and making good of all chases/ cuts etc. and discharging the drain into a floor trap/ gully as per site conditions with insulation, both as specified by the manufacturer.(make as approved by Architect/Bank)				
a	25 mm dia PVC drain pipe for Split AC	Mtr.	30.00		
b	32 mm dia PVC drain pipe for Cassette AC	Mtr.	80.00		







