

PROPOSED INTERIORS / RENOVATION FOR STATE BANK OF INDIA, B.O. AT MALIKPUR, DISTT. KURUKSHETRA, HARYANA

ELECTRICAL DB'S & UPS ROUTE

LEGEND

UPS LINE / ROUTE - 3 X 2.5 SQ.MM. PVC INSULATED COPPER CONDUCTOR ARMOURED CABLE

XX

3 NO. 5 AMP 3 PIN MODULAR SOCKET CONTROLLED BY 1 NO. 5 AMP MODULAR SWITCH WITH INDICATOR, CONNECTION END TERMINATIONS WITH SUITABLE SIZE OF GLANDS ETC. COMPLETE AS REQD. (ON UPS POWER).

NOTE - LED POINT AS PER BM ADVICE

XX

2 NO. 15 AMP 5 PIN MODULAR SOCKET CONTROLLED BY 1 NO. 15 AMP MODULAR SWITCH WITH INDICATOR, CONNECTION END TERMINATIONS WITH SUITABLE SIZE OF GLANDS ETC. COMPLETE AS REQD. (ON UPS POWER).

3X6 SQ.MM. COPPER CONDUCTOR (UPS DB'S)

LAYOUT PLAN - G.F.

	REV. D	ESCRIPTION	DATE
	TITLE: LAYO	OUT PLAN — . DB'S & UPS	ROUTE
	SCALE	1"=8'-0"	
	DATE	30/01/202	5
	JOB NO.	SBI-MP/01	
	DRG. NO.	WD-06	
CREATIVE CONCEP			PTS
		PLANNERS,INT.DE 1350, SECTOR	

PANCHKULA- 134116. PH. 09815788192 (M)