

| BOQ FOR THE PROPOSED WORKS OF RENOVATION/INTERIOR/FURNISHING OF BRANCH FOR STATE BANK OF INDIA | | | | | |
|---|---|----------------|------------|-----------------------------------|------------------|
| | | BRANCH DETAIL: | | DEVGURADIA_RBO2_BR, INDORE (M.P.) | |
| ELECTRICAL WORKS | | | | | |
| Note:- The rates quoted includes all other taxes , duties , loading, unloading , transportation, other expenses etc to site. only GST will be paid Extra | | | | | |
| I.No. | Description of items | Unit | Qty | in INR | |
| | | | | Rate Rs | Amount Rs |
| (A) | ELECTRICAL WIRING WORK | | | | |
| | Note: Use of Flexible conduits & Elbows in Circuit wiring is not allowed except in exceptional site conditions with the approval of Bank's Engineer / Architect and All wiring laying in the MS/PVC conduit strickle follow IE(Indian Electricity) rules, IS code, follow in all items of project/ work execution. Proper ferrules, lux, thimble , gland termination to be done in all cabling & wiring from both load/source end. Conduit carrying submain will not carry circuit/point wiring. Similarly conduit carrying circuit wiring will not carry submain/point wiring. Conduit carrying point wiring will not carry submain/circuit wiring. All Electrical works (Cabling/wiring/panel etc) to be carried out as per layout/General Arrangement (GA)Drawing attached only. | | | | |
| 1 | ELECTRICAL WIRING | | | | |
| | Wiring for light point/ fan point/ wall fan point/ exhaust fan/ light sockets etc. with 1.5 sq.mm. PVC insulated 1100 V Grade copper conductor (FRLS) wires & 1.5 sq.mm. copper earth wire in concealed/ surface using 16 SWG MS conduits, accessories such as bends, tees, saddles, draw boxes, mounting boxes, inner plates, cover plates, ceiling rose etc (wherever required) and chromium plates brass screws/ rowel plug etc. The circuit wiring starting from DB to point control box/ switch box using 2 X 2.5 sq.mm PVC insulated 1100 V grade multi- stranded copper conductor wire & 2.5 sq.mm. PVC insulated earth wire (color code to be used). (Flexible conduit/ elbow not allowed). The conduit to be laid in ceiling with proper clamps/ wall/ floor and filling the chase with cement mortar and finishing the same in original form/ wooden partition/ above false ceiling with proper clamps etc. all complete. | | | | |
| | (Wherever required as per standard specifications). | | | | |
| | i) Each circuit shall have independent earth wire. | | | | |
| | ii) Each point shall be earthed. | | | | |
| | iii) Circuit wiring is to be included in point wiring rates. | | | | |
| a | One light points controlled by one 6 amp. Modular switch. | Nos. | 27 | | |
| b | Two to Four light points controlled by one 6 amp. Modular switch. | Nos | 22 | | |
| c | One call bell point with ceiling rose/ 6amp. 3 pin socket controlled by one 6 amp. Push Modular switch. With call bell | Nos | 1 | | |
| d | Celing fan point with one nos 6 amp switch and 2 module electronic regulator including wiring & ceiling rose | Nos. | 7 | | |
| e | One 5 pin socket controlled by one 6 amp. Modular switch complete assembly includes plate box etc. on same light switchboard | Nos | 8 | | |
| 2 | 6 AMP. POINTS ON SEPARATE BOARD : | | | | |

ELECTRICAL WORKS

Note:- The rates quoted includes all other taxes , duties , loading, unloading , transportation, other expenses etc to site. only GST will be paid Extra

| I.No. | Description of items | Unit | Qty | in INR | |
|------------|--|------|-----|---------|-----------|
| | | | | Rate Rs | Amount Rs |
| a) | Same as serial no 1 but using 2*2.5 + 1*2.5 Sqmm Copper Conductor FRLS wires from DB to first 6A, 5 Pin modular socket controlled by one 6A switch and looped to the nearest second point with same 2*2.5 + 1*2.5 Sqmm copper conductor wires FRLS insulated 1100V grade (max 3 points per circuit). | | | | |
| i) | Primary Point | Nos | 12 | | |
| ii) | Secondary Point looped | Nos | 5 | | |
| 3 | Power Wiring (6 / 16 AMP. POWER POINTS) | | | | |
| | Same as serial no.1, but wiring for 16 Amp, 6-pin sockets by using 2*4 sq.mm. PVC insulated 1100 V grade copper conductor wire with independent 1* 4.0 sq.mm earth wire from D.B. to first point 1st socket and 1st to 2nd, socket with 2*2.5 sq.mm. and 1*2.5 earth wire including providing and fixing of 16 Amp, 6 -pin socket with 16 Amp. Switch. (Modular type switch/ socket/ plate etc. complete assembly) max 2 points per circuit. | | | | |
| i) | Primary Point | Nos | 14 | | |
| ii) | Secondary Point looped | Nos | 5 | | |
| 4 | AC/Geyser Point (Single Phase) | | | | |
| | Same as serial no.1, but wiring for A/C socket by using 2*4 sq.mm. PVC insulated 1100 V grade copper conductor wire and earthing with 1*4.0 sq.mm. PVC insulated 1100 V grade copper conductor wire with modular type AC box(tiny trip type) with socket complete in all respects controlled by 25/32 A SP MCB to be provided near indoor unit. The point starts from DB to stabilizer to the point near the indoor unit including top. | Nos | 3 | | |
| 5 | AC Point (Three Phase) | | | | |
| | Same as serial no.1, but wiring for A/C socket by using 4*6 sq.mm. PVC insulated 1100 V grade copper conductor wire and earthing with 1*6.0 sq.mm. PVC insulated 1100 V grade copper conductor wire of weather proof type 4 way SPN DB complete in all respects controlled by with 40 Amp TPN (10 KA) MCB to be provided near outdoor unit. The point starts from DB to the point near the outdoor unit. (includes wires for terminal connection of outdoor unit from TPN) | Nos | 2 | | |
| 6 | SPECIAL POINTS : (For Computers) | | | | |
| | Wiring with 2x2.5 sq.mm. + 1x2.5 sq.mm. PVC insulated 1100 V grade multi stranded copper conductor wires in 2 mm thick PVC conduit from UPS DB to computer point. Each point to have 3 nos. 6 amps. 5 pin modular type sockets, one 6 amps modular switch with all accessories, inner/ outer plates, metal box etc. and to be fixed on wooden partitions/ by grouting on wall etc. as per requirement at site. The switch should be fixed above the top of counter with indicator and sockets under the counter b) Same as above but looped from the above 1st point to 2nd , point and 2nd point to 3rd point. (Maximum 3 points in a circuit) | Nos | 9 | | |
| i) | Primary Point | Nos | 10 | | |
| ii) | Secondary Point looped | Nos | 5 | | |
| (B) | CONDUITING FOR TELEPHONE, COMPUTER & CONDUITING. WIRING FOR T.V. SYSTEM. | | | | |
| 7 | TELEPHONE POINT | | | | |

ELECTRICAL WORKS

Note:- The rates quoted includes all other taxes , duties , loading, unloading , transportation, other expenses etc to site. only GST will be paid Extra

| I.No. | Description of items | Unit | Qty | in INR | |
|---|--|-------|-----|---------|-----------|
| | | | | Rate Rs | Amount Rs |
| a | Wiring for VOICE from Jack Panel in data rack to computer workstation with Cat-6 voice cable in PVC conduits of size 20/ 25 mm including providing ferrules at both ends and termination at both ends including providing & fixing frame for Cat-6 with shutter, RJ 45 outlet, faceplate and mounting box complete of modular type. This work includes supply and laying of CAT-6 cable in PVC conduits throughout the length, from the I/O hub to the point. | Nos | 10 | | |
| | Supplying, laying, effecting terminations, testing and commissioning of 0.51 mm dia Cu. Conductor, twisted, colour coded with polythene capor barrier, telephone cables in the existing tray or in conduit including providing & fixing conduit pipe or cable tray as required from building tag block to the floor as required. | | | | |
| b | Supplying & fixing 20 pair krone tag block with enclosure. | Nos | 1 | | |
| c | P/L 10 Pair of PVC insulated PVC sheathed multi core jelly filled armored telephone. | Mtr | 65 | | |
| 8 COMPUTER NETWORKING | | | | | |
| a | Wiring for computer networking from Jack Panel in data rack to computer workstation with Cat-6 computer cable in PVC conduits of size 20/ 25 mm including providing ferrules at both ends and termination at both ends including providing & fixing frame for Cat-6 with shutter, RJ 45 outlet, faceplate and mounting box complete of modular type, This work includes supply and laying of CAT-6 cable in PVC conduits throughout the length, from the I/O hub to the point. | Nos | 20 | | |
| b | Supplying and fixing 9 U (Rack with glass door, opening in the front power panel 1 (horizontal), cable manager 1 lock & key). | Nos | 1 | | |
| c | Supply, Installation, Testing & Commissioning of 16 port Jack Panel. | Nos | 2 | | |
| d | Providing and fixing Patch Panels 8 port (100 base TX) CAT 6 patch/jack panel with connector, out lets and necessary connectivity complete as required & (D-Link make) | Nos | 3 | | |
| e | Providing and fixing of flowing factory fabricated Patch cords. (DBPS Mounting Cord) (UTP/CAT 6 complete with connector on both side.) | | | | |
| i) | Supplying and fixing Patch Cord-2 Meter- (DBPS Mounting Cord) | Nos. | 20 | | |
| ii) | Supplying and fixing Patch Cord-1 Meter- | Nos | 20 | | |
| 9 TV Point | | | | | |
| a | Supply and fixing of 1.6 mm thick G.I. Box along with RG 6 T.V Co axial socket with Cover Plate. | Nos | 1 | | |
| b | Supply, drawing, connecting, testing and commissioning of T.V Coaxial cable RG 6 in existing conduit. | R.Mtr | 40 | | |
| (C) CABLES AND DISTRIBUTION BOARDS | | | | | |
| 10 CABLES , MAINS & SUBMAINS | | | | | |
| | Supplying all materials and laying/ pulling 1100 volts grade PVC insulated copper conductor wires (FRLS) in MS conduit with all fixing accessories after cutting the floor, wall and the like etc. and replastering the floor level to original. Conduit must be 30 mm below the floor finish level. | | | | |
| i | 3.5 X 70 Sq.mm XLPE. Al. armoured Cable (AC VTPN, BUS BARS & A.C. DB)/Main cable | Mtr | 15 | | |

ELECTRICAL WORKS

Note:- The rates quoted includes all other taxes , duties , loading, unloading , transportation, other expenses etc to site. only GST will be paid Extra

| I.No. | Description of items | Unit | Qty | in INR | |
|-----------|--|------|-----|---------|-----------|
| | | | | Rate Rs | Amount Rs |
| ii | Supplying, laying, testing & commissioning of 4 C X 10 sq.mm. at 1100 volts grade PVC insulated copper conductor armoured cable with 10 gauge earth copper wire including cables end termination using appropriate Lugs, Glands, termination accessories, Clamps etc. as required as per specification from Main board to UPS Room | Mtr | 60 | | |
| iii | Supplying, laying, testing & commissioning of 4 C X 25 sq.mm. at 1100 volts grade PVC insulated aluminum conductor armoured cable with 10 gauge earth copper wire including cables end termination using appropriate Lugs, Glands, termination accessories, Clamps etc. as required as per specification Pane to (POWER/UPS) DB | Mtr | 50 | | |
| iv | Supplying, laying, testing & commissioning of 4 C X 16 sq.mm. at 1100 volts grade PVC insulated aluminum conductor armoured cable with 10 gauge earth copper wire including cables end termination using appropriate Lugs, Glands, termination accessories, Clamps etc. as required as per specification (Light DB). | Mtr | 35 | | |
| v | Supplying, laying, testing & commissioning of 4 C x 50 sq.mm. at 1100 volts grade PVC insulated aluminum conductor armoured cable with 10 gauge earth copper wire including cables end termination using appropriate Lugs, Glands, termination accessories, Clamps etc. as required as per specification (Mains). | Mtr | 20 | | |
| 11 | DISTRIBUTION BOARDS | | | | |
| | Note:-The Panel shall be approved by The Bank Authority before Placing the Panel order, otherwise it will not considered | | | | |
| | Supplying, installing, testing & commissioning of surface/recessed mountings, Double door 415 volts TPN MCB distribution board of steel steel, 1.6mm thick dust phosphatized and painted, inclusive of 100 amps, tinned copper busbars, earthbar, common neutral link, din bar for mounting of MCB's detachable gland / knock out plate & with built in loose wire box, and superior make terminal connectors for all incoming and outgoing circuits duly prewired with adequate size of PVC insulated copper wires between the bus bars and the MCB's as well as the incomer and upto the terminal connectors/ neutral link and ready for installation of following ways as required. | | | | |
| | Use 'B' curve MCB's for lighting & small power circuits, 'C' curve for motor duty i.e. for pumps, AC motors, window and split AC's etc. & 'D' curve for UPS DB's i.e. for computers/ PC's circuit. Main incomer & outgoing circuit MCB's shall be selected accordingly i.e. type B,C & D. Contractor to select the MCB's accordingly as per the nature of the circuit/ load. | | | | |
| | Each DB shall have separate neutral links of rating not less than 100A for each phase. The main incoming neutral link shall be in addition to three outgoing neutral links and shall be of 125 A | | | | |
| | UPS DB's shall have a dedicated Earthing link fixed on insulated supports, which will be in addition to body earth link | | | | |
| | All internal inter connecting wiring with in the DB's shall be PVC insulated flexible copper conductor wires of adequate capacity as per the current rating. | | | | |
| | Inside each DB, a DB chart is to be fixed. | | | | |
| a | 6-way TPN DB (LIGHT DB) | Set | 1 | | |
| | Incomer:- | | | | |

ELECTRICAL WORKS

Note:- The rates quoted includes all other taxes , duties , loading, unloading , transportation, other expenses etc to site. only GST will be paid Extra

| I.No. | Description of items | Unit | Qty | in INR | |
|-------|---|------|-----|---------|-----------|
| | | | | Rate Rs | Amount Rs |
| 13 | LED LUMINARES:- 2' x2' (FULL GLOW TYPE) LED light fittings (600 X600mm) dimension suitable for grid/gypsum ceiling complete with its electronic driver as required per instruction of Bank's Model No are as under:- PHILIPS:- RC380B G2 LED 35S-6500 PSU OD WH LED (FULLGLOW) WIPRO:- CRCO1ORO 38 HP57 HAVELLS:- LHECDIL7IL1W036 (Edge- Lit) CG:- LCTAR3-40-CDL | Nos | 14 | | |
| 14 | LED DOWNLIGHTER (Recessed): 15 Watt, recessed mounted circular down lighter , 6" dimension with complete its electronic driver are as under:- PHILIPS:- GREENLED-DN193B LED-12S-6500 PSU WIPRO:- IRIS LED LD 71-121-XXX-50-XX HAVELLS:- LHEBJNP ZPZ 1W 015(ENDURA LOW DEPTH) CG:- LC DD-15-CDL, | Nos | 11 | | |
| 15 | LED DOWNLIGHTER (Surface Mounted): 15 Watt, recessed mounted circular down lighter , 6" dimension with complete its electronic driver are as under:- PHILIPS:- GREENLED-DN193B LED-12S-6500 PSU WIPRO:- IRIS LED LD 71-121-XXX-50-XX HAVELLS:- LHEBJNP ZPZ 1W 015(ENDURA LOW DEPTH) CG:- LC DD-15-CDL, | Nos | 5 | | |
| 16 | LED Spot Light, 3 Watt, 2/3"(Inches) size as per site requirment. PHILIPS, WIPRO, HAVELLS, CG | Nos | 15 | | |
| 17 | LED 18 watt Tube Light 1200mm with all accessories.make As specified in tender document or approved by bank | Nos | 6 | | |
| 18 | LED 9 watt Tube Light 600mm with all accessories.make As specified in tender document or approved by bank | Nos | 3 | | |
| 19 | LED COVE / STRIP LIGHT WITH ITS ELECTRONIC DRIVER(BLUE COLOUR):- Supply, installation, testing and commissioning of bright LED strip light with its electronic driver complete as required. PHILIPS, WIPRO, HAVELLS, CG | Mtr | 50 | | |
| 20 | BLDC (Brushless Direct Current) FANS FIVE STAR RATING Single phase heavy duty grease filled double ball bearing, aerodynamically designed heavy gauge aluminium blades, copper wound and impregnated silicon stamping motors etc 1200 mm sweep, brilliant white CG/ USHA/ ORIENT/ HAVELLS | | | | |
| i) | Ceiling Fan 1200mm dia | Nos | 9 | | |
| ii) | Oscillating wall fan (Metallic Body) Sweep 400/450 mm , RPM 1300 | Nos | 5 | | |

ELECTRICAL WORKS

Note:- The rates quoted includes all other taxes , duties , loading, unloading , transportation, other expenses etc to site. only GST will be paid Extra

| I.No. | Description of items | Unit | Qty | in INR | |
|--|--|------|-----|---------|-----------|
| | | | | Rate Rs | Amount Rs |
| 21 | EXHAUST FAN:- Single phase, 300mm sweep, 900 rpm, metallic exhaust fan of the following single phase Exhaust fan continuously rated, capacitor start and run type, totally enclosed and ruggedly built, pre lubricated double ball bearing, copper wounded, A & E class insulation, dynamically balanced, below 40 db sound level etc, front cover with grill/gravity louver for protection purpose with 12 mm plywood complete in all respect make as under: CG/USHA/ORIENT/HAVELLS/ALMONARD/ALSTOM | Nos | 3 | | |
| 22 | CALL BELL: Electronic Bell with battery backup, simple ding-dong type, each unit to have a different sound. | Nos | 1 | | |
| 23 | "S" TYPE M.S. FAN HOOKS:- Supplying & Fixing "S" Type Fan Hooks in Ceiling of R.C.C. Slab by Cutting, Chiseling & Making Good all the Damages with 1:4 Cement Sand Mortar wherever required, Painting, Cleaning the Site etc., as per Instructions of the Architect | Nos | 9 | | |
| 24 | STEEL DOWN RODS:- Supply & Fixing of M.S. Down Rods up to 1.00Mt. length, wherever required, with necessary Ball Sockets, Anchor Fasteners etc., complete as per Instructions of the Architect. | Nos | 9 | | |
| 25 | Providing & fixing of "Digital Clock" /Digital Panel indicating Time, Day, Date, Temperature at outside of big size,(Ajanta - OLC-1070) as suitable over the facade as advised by the Bank with standard power back up. Make:- Ajanta, Titan | Nos | 1 | | |
| (E) EARTHING, MAIN PANEL, METER BOARD | | | | | |
| 13 | EARTHING SYSTEM | | | | |
| a | Supply, Installation, Testing and Commissioning of Maintenance Free Earthing system made up of copper-bonded rod of 10 feet length, 23 mm dia. (Minimum copper bonding shall be 0.25mm) along with Rod-to-Conductor connectors, Earth enhancement material, Pit Cover and other accessories as required and as per specification and other applicable codes (include chamber for earthing, Earthing certificate to be submitted along with the bill). | Nos | 1 | | |
| b | Supply, Installation, Testing and Commissioning of Maintenance Free Earthing system made up of GI rod of 10 feet length, 17.2 mm dia. along with Rod-to-Conductor connectors, Earth enhancement material, Pit Cover and other accessories as required and as per specification and other applicable codes (include chamber for earthing, Earthing certificate to be submitted along with the bill). | Nos | 1 | | |
| c | Providing and fixing of Copper/ GI strips in surface or in recess for loop earthing etc. as required. | | | | |
| i) | Copper Strip 25 mm x 3 mm with proper clamps | Mtr. | 6 | | |
| ii) | G.I.Strip 25 X 5 mm | Mtr | 25 | | |
| iii) | Providing and fixing 2 X 8 SWG dia. Cu earth wire in PVC conduit on surface or in recess for loop earthing along with the existing surface/ recess cable as required.(Dedicated Earthing for UPS output DB only) | Mtr. | 30 | | |
| 14 | MAIN PANEL AND METER BOARD | | | | |

ELECTRICAL WORKS

Note:- The rates quoted includes all other taxes , duties , loading, unloading , transportation, other expenses etc to site. only GST will be paid Extra

| I.No. | Description of items | Unit | Qty | in INR | |
|-------|---|------|-----|---------|-----------|
| | | | | Rate Rs | Amount Rs |
| | Designing, fabrication, supply, installation, testing and commissionings of front operated cubicle type compartmentalised, front access, free standing on 75MM "I" MS channel, dust and vermin proof (IP 42 degree protection) panel suitable for use at 415V, 3 phase, 4-wire 50Hz system suitable for fault level of required value symmetrical at 415V fabricated from 2mm thick CRCA MS sheets with hinged, gasketted (Metal based neoprene) locable doors having structural reinforcement including 3mm thick gland plates on top and bottom, lifting hooks, GI earth strip of required size with 2 nos earth terminals, 2 nos 230V AC operated 250mm X 250mm size axial fans for exhaust of heat with On-Off toggle switches including 2 coated primer and 2 power coated paint finish of approved shade over metal surface cleaned and treated with seven tank process complete with interconnections etc as per specifications as required.main panel board of approved make (KRYPTON POWER CONTROLS/NEPTUNE/TRICOLITE/AMPTECH Or should be CPRI Approved, Type of Approval as instructed by the SBI/Architect)as per the following specifications,should be CPRI Approved. | | | | |
| | All live accessible parts shall be shrouded and all equipment shall be finger touch proof. The busbars insulation shall be with heat shrinkable sleeves SMC/ DMC shrouds and busbar supports shall be used. Padlocking facility shall be provided on all outgoing feeders doors and switch handles shall be locable in OFF position. | | | | |
| | Suitable arrangement shall be made for termination of multiple incoming cables. | | | | |
| | All kA values indicated shall be Ics breaking capacity | | | | |
| | GA drawings shall be got approved by SBI | | | | |
| a | Fabrication, supply, installation, testing and commissionings of cubicle type floor/wall mounted L.T. panel made out of 2 mm thick CRCA sheet including connection, inter-connection alongwith 4 strip aluminium busbar as per CPWD specifications,(Part IV-Sub-station) etc. as required.(Meter Board) | | | | |
| | Incoming :- | | | | |
| | i) 1no. 125 Amp 4P MCCB (25 KA) thermal over current, instantaneous, Short circuit release, Earth fault. | | | | |
| | ii) Busbar :-200 Amps 4P aluminum conductor bus bar (BPTM type Heat-shrinkable busbar insulation) supported by DMC / FRP insulators | | | | |
| | Space shall be provide for the BSES Meter | | | | |
| | Meter board shall be lockable. | | | | |
| | Complete panel described as above. | | | | |
| | | | | | |
| b. | Floor panel shall consists of : - | | | | |
| | INCOMER | | | | |
| | 1no. 125 Amp 4P On Load Change over switch with 1 No. 125 Amps, TPN MCCB (25 KA) with extendible rotary handle each thermal over current, instantaneous, Short circuit release, Earth fault. | | | | |
| | | | | | |
| | BUSBARS | | | | |
| | 125 amps TPN pole busbar chamber of suitable length with copper busbars. All busbars and interconnections shall be of suitable size copper strips. | | | | |
| | | | | | |
| | INDICATING PANEL | | | | |

ELECTRICAL WORKS

Note:- The rates quoted includes all other taxes , duties , loading, unloading , transportation, other expenses etc to site. only GST will be paid Extra

| I.No. | Description of items | Unit | Qty | in INR | |
|-------|--|------|-----|-----------|-----------|
| | | | | Rate Rs | Amount Rs |
| | Digital flush type class-1.0 accuracy multifunction meter showing V, A, PF etc. with 3 Nos. current transformers of 100/5A ratio, 10 VA Class-1.0 metering. - 1 sets | | | | |
| | Red/Green/Amber ON/OFF/TRIP indicating lamps with 2A SP MCB backup protection. | | | | |
| | 1 set of three phase indicating lamps along with 2A SP MCB backup protection. | | | | |
| | Restricted Earth fault relay with 3 Nos. current transformers of 160/5 ratio, 15 VA Class 5P 10 (Numeric Relay not required) | | | | |
| | Undervoltage, Overvoltage & phase reversal relay for persisted voltage of 105-180% & 20-95% of rated voltage. (Numeric Relay not required) | | | | |
| | OUTGOINGS:- | | | | |
| | 3 Nos 63A TPN MCCB (16 kA) for Power, Electrical & AC terminals suitable to receive cable on one side and wire connection to Bus bars. For capacitor Bank AND AC VTPN, | | | | |
| | 2 Nos 63A TPN MCB (10 kA) terminals suitable to receive cable on one side and wire connection to Bus bars. (For PDB UPS) | | | | |
| | 1 Nos 40A TPN MCB (10 kA) terminals suitable to receive cable on one side and wire connection to Bus bars. (For LDB) | | | | |
| | 2 Nos 40A DP MCB (10 kA) terminals suitable to receive cable on one side and wire connection to Bus bars. | | | | |
| | The electrical panel as described above and specifications complete. | Set | 1 | | |
| | c Supplying, installation, testing & commissioning of 12.5 KVAR, APFC Panel autooperation and power factor should be nearing unity complete as required including all contactors, relays, indicating units etc. as required at site". Capacitor make: L&T/ ABB/ Siemens/ Neptune | set | 1 | | |
| | TOTAL OF ELECTRICAL WORKS | | | Rs | |

IN WORDS Rs.