

**Price bid for SITC of Down comer system (Hose Reel/Terrace Pump & Accessories) at RBO
Ratlam building**

S.No	Item Description	Quantity	Unit	Rate per unit (Rs.)	Amount
1	SITC of Fire Bridage Inlet (2 way) with 63 mm dia instaneous inlet complete with all necessary fittings and Stainless Steel NRV. (MAKE – NEW AGE/ GEI /AAAG or other equivalent ISI Mark)	2	Nos		
2	SITC of Cast iron body Non-Return valves (NRV) PN1.6 dual plate with matching flanges, rubber insertion, nuts, bolts and washer etc. of following sizes complete as reqd. (Make:Sant /Kartar/New Age/Audco/other equivalent ISI Mark)				
a	100 mm dia	2	Nos		
b	80 mm dia	1	Nos		
3	Supply, fixing, testing commissioning of butterfly valve PN 1.6, with Bronze/ Gunmetal seat duly ISI marked complete with Nuts, Bolts, washers, gaskets, conforming to IS 13095, of following sizes as required. (MAKE – NEW AGE/ SWATI/Lifeguard /Kartar/other equivalent ISI Mark)				
a	100 mm dia	3	Nos		
4	Providing, fixing, testing and commissioning of Above Ground M.S. ERW Black C Class Heavy duty pipes as per IS: 1239 including cutting, screwing, welding etc. and providing all fittings like flanges, bends, tees, elbows, reducers, clamps, hangers etc. with painting of one coat of primer and 2 or more coats of synthetic enamel paint of approved make / shade complete as per specification (MAKE TATA/ JINDAL/ Nezone/other equivalent ISI Mark)				
a	100 mm dia	120	RMT		
b	80 mm dia	30	RMT		
c	25 mm dia	10	RMT		
5	SITC of Fire Aid Hose Reel Drum with 30mtrs long thermoplastic hose type 2 as per IS:12585 and GM shut off nozzle 25 mm dia Gate Valve, Union pipe complete set confirming to IS: 884 (MAKE – NEW AGE/ AAAG/ SWATI /Lifeguard / other equivalent ISI Mark)	6	Nos		
6	Providing, fixing, testing & Commissioning of Single headed ISI Marker Oblique pattern Stainless steel Hydrant Landing valve with 80 mm dia, flanged inlet & 63 mm dia instantaneous type female outlet complete with cap and chain twist release lug and all accessories as per IS : 5290-1983 (Type -'A') and specifications complete as required. (MAKE – NEW AGE/SWATI/ Lifeguard/Shah Bhogilal/ Ghosh Engg/ New Age/ Safex or other ISI Mark)	6	Nos		
7	Providing & Fixing of weather proof hose cabinets fabricated from 18 S.W.G M.S Sheet with Centre opening full front glass door and locking arrangement suitable to accommodate 2nos 15M Long hoses and 1 no. Branch Pipe with nozzle. The cabinet shall be painted with one coat of primer and 2 or more coats of synthetic enamel paint of approved make & shade and shall be suitably mounted on a raised masonry platform complete as reqd.(Make - Self Fabricated) 750 X 600X 250 MM	5	Nos		

8	Providing RRL Hose with ISI Marked (IS:636) 63 mm dia X15 M long complete with instantaneous type Stainless Steel 63 mm dia ISI Marked male & female couplings (IS: 903) bound & riveted to hose pipes with SS rivets and SS wire complete as required. (MAKE: Shah bhogilal/Newage/Lifeguard/BRG or equivalent ISI Mark)	7	Nos		
9	Providing & Fixing of Stainless Steel 63 mm dia Short Branch Pipe 20 mm dia nozzle , ISI marked (IS: 903) complete as required.(MAKE– Shah Bhogilal/ Ghosh Engg/ New Age/Lifegaurd/ SWATI/TULSI/ or other equivalent ISI Mark)	4	Nos		
10	Supply & fixing of 100mm dia bourden type glycerin filled, Stainless steel dial type pressure gauge(0 - 16 Kg) range, 3 / 8 " BSP bottom entry on Pump Delivery Line complete with Ball valve (Wikai/ Waree/ baumar /Guru/other equivalent ISI Mark)	4	Nos		
11	Supply & fixing of Pressure switches for automatic operation of pumps, including necessary wiring upto control panel and Ball valve. (Make Potter/Indfos or other equivalent ISI Mark)	1	Nos		
12	Supply, Installation, Testing & Commissioning of Electric Driven Terrace Monoblock pump for Hydrant applications suitable for automatic operation (Make- KIRLOSKAR / Mather & platt /ABB/Siemens/Lubi/other equivalent ISI Mark)				
a	7.5 HP 450 LPM suitable for 24 Mtr Head, single stage	1	Nos		
13	SITC of Starter Panel, Fabricated for capable of Operation of 450 / 900 LPM Terrace Pump or capable of start up to 10 HP pump and having provision for automatic starting by pressure switches, control mounting shall include necessary lamps indications, ammeters for motor full load circuit with CTs and selector switch, auto/manual selector switch voltmeter with selector switch controlling push button etc. The panel shall be duly painted with protective anticorrosive and shall be foot mounted/wall mounted type including all accessories. (Make- L&T/ ABB/ Siemens/other equivalent ISI Mark)	1	Nos		
14	SITC of 3C X 4 sq mm, Copper PVC Shielded Cable suitable to run 7.5 HP/ 5.0 HP pump on maximum load (Fire Panel to Terrace PUMP) (Make- Polycab/ Finolex/ RR Kable/ KEI/other equivalent ISI Mark)	50	RMT		
15	Supplying, fixing and placing plastic cylindrical vertical closed top three layers (PVC) tank at the terrace over the staging with manhole cover with locking and cleaning arrangement including arrangements of overflow (Flot valve e.t.c), water filling from existing arrangements available at branch and also providing proper iron base stand of suitable thickness (approx. 300 kg weight) and height of standard tank diameter as required to hold the weight of tank on the terrace, and others connection etc. if required. (Make: Sintex / Polycon or equivalent ISI mark)				
a	5000 ltr	2	Nos		
16	Providing and fixing gunmetal of single acting air release valve with screwed inlet 25 mm dia. (Make: Zoloto/ Karter/ Kitz/ other equivalent ISI Mark)	1	Nos		
17	Miscellaneous Civil work including 02 core cutting	1	Nos		
18	LED FIRE EXIT Signages	2	Nos		
19	Underground trenching and wrapping coating	15	mtr		

Grand Total (Excluding GST)		

--	--

--	--