



State Bank of India

Premises Department, 9th Floor State Bank of India,

Corporate Office, Nariman Point, Mumbai – 21.

Phone No. 022-22740930, e-mail: dgmpremises.cc@sbi.co.in

CORRIGENDUM TO TENDER ID NO. SBI/CC/FIRE/PKY/01 dated 22.06.2026

PROPOSED UPGRADATION AND SUPPLY, INSTALLATION, TESTING & COMMISSIONING (SITC) OF FIRE PREVENTION, FIRE PROTECTION AND BUILDING MANAGEMENT SYSTEM (BMS) AT STATE BANK BHAVAN BUILDING MUMBAI

It has been decided by competent authority to update the parts/clause of the tender notice as under:

SI No	RPF Pg No	RFP Clause No.	Existing Clause	Revised Clause
1	269	Letter of Declaration.	Earnest Money Deposit (EMD) b). Rs 12,50,000/- only (Rupees Twelve lakh fifty thousand only), by means of Demand Draft / Pay Order from any scheduled Commercial /Nationalized Bank drawn in favour of "SBI and payable in "Mumbai". Valid for 90 days from the date of tender file.	b). Rs 14,87,000/- only (Rupees Fourteen lakh eighty-seven thousand only), by means of Demand Draft / Pay Order from any scheduled Commercial / Nationalized Bank drawn in favour of "SBI and payable in "Mumbai". Valid for 90 days from the date of tender file.
2	138	Section-3 Suction & Delivery piping Part A, Point 9.0	-	Approved make of paint – Ameetuff technical paints Industries, Ugam Chemicals and Rudra Paint.
	140 - 141	Isolation Valve Point 13.0	Isolation valve of Butterfly valve type to be of Wafer type design, suitable for working pressure of 16 kg(f)/ sq.cm and 24 kg(f)/sq.cm.	Wherever PN 24 appears in the RFP, may be read as PN 25.
	144	SITC of GI ERW pipe as per IS 1239, Heavy Gauge -Part A, No. 2, Point 1.	Fire resistant silicon epoxy coating.	Make of paint – Ameetuff technical paints Industries, Ugam Chemicals and Rudra Paint.

Other terms and conditions of the tender will remain same.

Date: - 06.07.2026

General Manager (OL & CS)